EMERGENCY EYEWASH & SHOWER MAINTENANCE LOG

Eyewash/Shower stations require weekly checks to be compliant with the American National Standards Institute which OSHA may reference during an inspection.

Weekly checks include:

1. Access: pathway to eyewash/shower station must be free of obstructions.
2. Signage: Eyewash/shower station should be easily identifiable.
3. Water from eyewashes and showers must be sediment free.
4. Water should be tepid (lukewarm).
5. Eyewashes:
   a. Must be run for at least three minutes.
   b. Must come on within one second of activation.
   c. Flow must be adequate to remove eyepiece covers and remain at a steady pressure in both eyepieces.
   d. Eyepieces should be disinfected with 10% bleach solution or 70% alcohol then flushed with water for 15 seconds. Replace eyepiece.

LOCATION: _____

UAF FS NUMBERS:

Eyewash: _____ Shower: _____

☐ Eye Wash Station
☐ Eye/Face Station
☐ Drench Hose
☐ Shower
☐ Other: _____

Date	Access & Signage	Eyewash 3 minute flush	Eyepiece cleaned	Shower Activated	Notes/Corrective Action Taken	Initials

Date	Access & Signage	Eyewash 3 minute flush	Eyepiece cleaned	Shower Activated	Notes/Corrective Action Taken	Initials